

Certificate

Passive House Suitable Component

For cool temperate climates, valid until 31. December 2021

Category: **Compact Heat Pump System**

Manufacturer: **Nilan A/S**

8722 Hedensted, DENMARK

Product name: **Compact P (172 m³/h)**

This certificate was awarded based on the following criteria (limit values*):

Thermal Comfort: $\theta_{\text{supply air}} \geq 16,5^{\circ}\text{C}$
 Heat Recovery of ventilation system: $\eta_{\text{WRG,eff}} \geq 75\%$
 Electric efficiency ventilation system: $P_{\text{el}} \leq 0,45 \text{ Wh/m}^3$
 Air tightness (internal/external): $V_{\text{Leakage}} \leq 3\%$
 Total Primary Energy Demand (**): $PE_{\text{total}} \leq 55 \text{ kWh}/(\text{m}^2\text{a})$
 Control and calibration (*)
 Air pollution filters (*)
 Anti freezing strategy (*)
 Noise emission and reduction (*)

**Measured values to be used in PHPP (set point 172 m³/h)
useful air flow rates 120 to 205 m³/h**

Heating

| | | Test point 1 | Test point 3 | Test point 3 | Test point 4 | |
|---|-------------------------------|----------------|---------------|---------------|--------------|----|
| Outside Air Temperature | T_{amb} | -3.7 °C | 2.0 °C | 6.9 °C | | °C |
| Thermal Output Heating Heat Pump | P_{heating} | 0.61 | 0.78 | 0.92 | | kW |
| COP number Heating Heat Pump | $\text{COP}_{\text{Heating}}$ | 2.65 | 3.18 | 3.58 | | - |
| Maximum available supply air temperature with Heat Pump only(*) | | 28.6 | | | | °C |

Hot water

| | | Test point 1 | Test point 3 | Test point 3 | Test point 4 | |
|---|--------------------------------------|----------------|---------------|---------------|----------------|-------------------|
| Outside Air Temperature | T_{amb} | -4.0 °C | 2.0 °C | 7.0 °C | 20.2 °C | °C |
| Thermal Output Heat Pump for heating up storage tank. | $P_{\text{DHW heating up}}$ | 0.60 | 0.83 | 0.99 | 1.14 | kW |
| Thermal Output Heat Pump for reheating storage tank | $P_{\text{DHW reheating}}$ | 0.53 | 0.82 | 0.95 | 1.05 | kW |
| COP Heat Pump for heating up storage tank | $\text{COP}_{\text{DHW heating up}}$ | 2.13 | 2.87 | 3.31 | 3.68 | - |
| COP Heat Pump for reheating storage tank | $\text{COP}_{\text{DHW reheating}}$ | 1.81 | 2.72 | 3.05 | 3.28 | - |
| Average storage tank temperature | | 50.5 | | | | °C |
| Specific storage heat losses | | 1.63 | | | | W/K |
| Exhaust air addition (if applicable) | | | | | | m ³ /h |

(*) detailed description of criteria and key values see attachment.

(**) for heating, domestic hot water (DHW), ventilation, auxiliary electricity in the reference building, explanation see attachment.

Heat Recovery

$$\eta_{\text{WRG,eff}} = 80\%$$

Electric efficiency

$$0.40 \text{ Wh/m}^3$$

Air tightness

$$V_{\text{leak, internal}} = 1.0\%$$

$$V_{\text{leak, external}} = 1.1\%$$

Frost protection

down to -4°C

Total Primary Energy Demand (**)

51.4 kWh/(m²a)

